

Water Testing Laboratories

PO Box 4547

(P) 410-546-1318 Salisbury, MD 21803 (F) 410-546-5028

thewaterlab@yahoo.com2011

St. Martin's by the Bay
 Sharp Water
 129 Columbia Rd.
 Salisbury, MD 21801

Lead and Copper Analysis

PWSID# 0-23-0008

<u>Location</u>	<u>St. Martin's by the Bay</u>	<u>Samples</u> <u>Collected On:</u>	<u>Lead, mg/l</u>	<u>Date</u>	<u>Copper, mg/l</u>	<u>Date</u>	<u>Lab #</u>
11311 Marina Dr. #50		10/6/2011	ND	10/16/2011	ND	10/17/2011	214
11746 Riverview Dr. Kitchen		10/6/2011	ND	10/16/2011	ND	10/17/2011	214
11718 Riverview Dr. Kitchen Sink		10/6/2011	ND	10/16/2011	ND	10/17/2011	214
11305 Marina Dr. #40		10/6/2011	ND	10/16/2011	ND	10/17/2011	214
11311 Marina Dr. #49 Kitchen Sink		10/6/2011	ND	10/16/2011	ND	10/17/2011	214

Method

EPA 200.9

SM 3111B

Detection Level

0.005

0.05

Allowable Limit

0.015

1.3

ND=Not Detected

Reported by: Fred Grozinger

Lab Certification # 104